



Verona Fire Department
101 Lincoln Street
Verona, Wi 53593

Emergency Calls: 911
Business Calls: 608-845-9401
Business Fax: 608-845-9455

October 23, 2008

General and sprinkler contractors please note:

In previous editions of the IFC and NFPA there was a distance requirement as to how far away a fire hydrant had to be from the fire department connection. This distance ranged from 100 to 150 feet. In the current editions this distance requirement has been removed and both now state the locations shall be approved by the authority having jurisdiction.

It is the policy of the Verona Fire Department to keep the distance from a fire hydrant to a fire department connection no more that 150 feet apart.

If you have any questions regarding this policy or how it will relate to your project please feel free to call me at 608-845-9401.

Thank you,

Captain Alex Miller
Fire Prevention Inspector
Verona Fire Department